



Burning Permit Instructions

The City Of Yukon Fire Department

FIRE DEPARTMENT

Before any material may be burned in the City of Yukon, the conditions listed below must be met in accordance with: The Oklahoma Fire Prevention Code, the Oklahoma Clean Air Act, Oklahoma Statutes Title 27A, 2/5101 et. Seq.; and the Oklahoma Administrative Code, 252:100-13.

- A.** A site visit is required by the fire officer prior to issuance of the permit.
- B.** A "permit to Burn" must be obtained from the City of Yukon Fire Department **prior** to the ignition of any material.
- C.** Permission to burn must be obtained **each day** that burning is to take place by calling **405/354-2133**
- D.** Burning shall not be initiated until three (3) hours after sunrise; Additional fuel shall not be added three (3) hours prior to sunset. **Burning sites shall be attended at all times and the conditions of the permit strictly adhered to. All fires must be completely extinguished by dark.**
- E.** Adequate fire protection shall be provided by permit holders such as hose, nozzle, and water supply and/or earth-moving equipment as noted on the approved burn permit.
- F.** Prevailing winds at the time of burning must be away from urban areas of town.
- G.** Material to be burned shall be limited to **vegetative material**. Care must be used to minimize the amount of dirt on the material being burned.
- H.** Oils, rubber and other similar materials that produce unreasonable amounts of air contaminants shall not be burned.
- I.** The burning must be controlled so that a traffic hazard is not created as a result of air contaminants.
- J.** Required Distances: **(1)** Land clearing/land management burning activities – 500 feet clearance from adjoining occupied residences **AND (2)** Brush burning activities – 150 feet clearance from any structure.
- K.** The area surrounding the burn site must be cleared as determined by the Fire Officer issuing the Burn Permit.
- L.** The wind speed must be less than 15 miles per hour, as indicated by the National Weather Service forecast each day. Inversion factor minimum of 1000' ceiling.
- M.** No permit holder or any other person shall burn any material within 1000 feet of any oil and gas well locations of surface equipment.